(954) 752-9443 (888) 505 0828
FLEET INSPECTIONS since 2007
Performing Residential & Commercial Property Inspections

CITIZENS BUILDING TYPE II AND III MITIGATION INSPECTION FORM

This Mitigation Inspection Form must be completed to capture mitigation features applicable to a Type II (4-6 story) or Type III (7 or more story) building. This Inspection Form is required for either residential condominium unit owners or commercial residential applicants requesting mitigation credits in such buildings.

WIND LOSS MITIGATION INFORMATION				
PREMISES #		SUBJECT OF INSURANCE:	**HUNTINGTON LAKES SECTION FOUR**	POLICY #:
BUILDING#:	**32**	PROPERTY ADDRESS:	**7340 AMBERLY LN, DELRAY BEACH FL 33446**	
# STORIES	**4**	BUILDING DESCRIPTION:		
BUILDING TYPE:	**II (4 to 6 stories)**			

Terrain Exposure Category must be provided for each insured location.

I hereby certify that the building or unit at the address indicated above TERRAIN EXPOSURE CATEGORY as defined under the Florida Building Code is (Check One):

[X] Exposure C [ ] Exposure B

Certification below for purposes of TERRAIN EXPOSURE CATEGORY above does not require personal inspection of the premises.

Certification of Wind Speed is required to establish the basic wind speed of the location (Complete for Terrain B only if YearBuilt On or After Jan.1, 2002).

I hereby certify that the basic WIND SPEED of the building or unit at the address indicated above based upon county wind speed lines defined under the Florida Building Code (FBC) is (Check One):

[ ] >100 [ ] >110 **[X] >120**

I hereby certify that the building or unit at the address indicated above is designed and mitigated to the Florida Building Code (FBC) WIND DESIGN of (Check One)

Certification of Wind Design is required when the buildings is constructed in a manner to exceed the basic wind speeddesign for the structure location (Complete for Terrain B if Year Built On or After 1.1, 2002).

[ ] >100 [ ] >110 **[X] >120**

Certification for the purpose of establishing the basic WIND SPEED or WIND SPEED DESIGN above does not require personalinspection of the premises.

Specify the type of mitigation device(s) installed:

NOTE: Any documentation used in validating the compliance or existence of each construction or mitigation attribute must accompany this form. At least one photo documenting the existence of each visible and accessible construction or mitigation attribute marked in Sections 1 through 4 must accompany this form.

1. Roof Coverings

Roof Covering material: **BUILT UP** **Date of Installation:** **4/27/11**

Level A (Non FBC Equivalent) – Type II or III

One or more roof coverings that do not meet the FBC Equivalent definition requirements below.

[X] **Level B (FBC Equivalent) – Type II or III**

Single-Ply, Modified Bitumen, Sprayed Polyurethane foam, Metal, Tile, Built-up, Asphalt Shingle or Rolled Roofing, or other roof covering membranes/ products that at a minimum meet the 2001 or later Florida Building Code or the 1994South Florida Building Code and have a Miami-Dade NOA or FBC 2001 Product Approval listing that is/was current at the time of installation.

All mechanical equipment must be adequately tied to the roof deck to resist overturning and sliding during high winds. Any flat roof covering with flashing or coping must be mechanically attached to the structure with face fasteners (no clip/cleat systems), and asphalt roof coverings on flat roofs must be 10 years old or less.

CITIZENS BUILDING TYPE II AND III MITIGATION INSPECTION FORM

2. Roof Deck Attachment

Level A – Wood or Other Deck Type II only

Roof deck composed of sheets of structural panels (plywood or OSB).
Or
Architectural (non-structural) metal panels that require a solid decking to support weight and loads.
Or
Other roof decks that do not meet Levels B or C below.

Level B – Metal Deck Type II or III

Metal roof deck made of structural panels fastened to open-web steel bar joists and integrally attached to the wall

[X] **Level C – Reinforced Concrete Roof Deck Type, II or III**

A roof structure composed of cast-in-place or pre-cast structural concrete designed to be self-supporting andintegrally attached to wall/support system.

3. Secondary Water Resistance REINFORCED

[ ] Underlayment. A self-adhering polymer modified bitumen roofing underlayment (thin rubber sheets with peel & stick underside located beneath the roof covering and normal felt underlayment) with a minimum width of 6" meeting the requirements of ASTM D 1970 installed over all plywood/OSB joints to protect from water intrusion. All secondarywater resistance products must be installed per the manufacturer's recommendations. Roofing felt or similar paper based products are not acceptable for secondary water resistance.

[ ] Foamed Adhesive. A foamed polyurethane sheathing adhesive is applied over all joints in the roof sheathing to protect interior from water intrusion.

4. Opening Protection [X] None or Some

Class A (Hurricane Impact) – All glazed openings (windows, skylights, sliding glass doors, doors with windows,etc) less than 30 feet above grade must be protected with impact resistant coverings (e.g. shutters), impact resistant doors, and/or impact resistant glazing that meet the Large Missile (9 lb.) impact requirements of:

SSTD12;

ASTM E 1886 and ASTM E 1996;

Miami-Dade PA 201, 202, and 203;

Florida Building Code TAS 201, 202 and 203;

All glazed openings less than 30 feet above grade shall meet the Large Missile Test standard referenced above. All glazed openings between 30 and 60 feet above grade must meet the Small Missile Test of the respective standard. For buildings located in the HVHZ (High Velocity Hurricane Zone) all glazed openings greater than 60 feet above grade must also meet the Small Missile Test of the respective standard.

Class B (Basic Impact) – All glazed openings (windows, skylights, sliding glass doors, doors with windows, etc) less than 30 feet above grade must be protected with impact resistant coverings (e.g. shutters), impact resistant doors, and/or impact resistant glazing that meet the Large Missile (4.5 lb.) impact requirements of:

ASTM E 1886 and ASTM E 1996

All glazed openings less than 30 feet above grade shall meet the Large Missile Test standard referenced above. All glazed openings between 30 and 60 feet above grade must meet the Small Missile Test of the respective standard. For buildings located in the HVHZ (High Velocity Hurricane Zone) all glazed openings greater than 60 feet above grade must also meet the Small Missile Test of the respective standard.

(954) 752-9443 (888) 505 0828
FLEET INSPECTIONS since 2007
Performing Residential & Commercial Property Inspections

CITIZENS BUILDING TYPE II AND III MITIGATION INSPECTION FORM

CERTIFICATION

I certify that I hold an active license as a: (*CHECK ONE OF THE FOLLOWING*)

- [X] General or building contractor licensed under Section 489.111, Florida Statutes.
- ☐ Building code inspector certified under Section 468.607, Florida Statutes.
- ☐ Professional architect licensed under Section 481.213, Florida Statutes.
- ☐ Professional engineer licensed under Section 471.015, Florida Statutes.

I also certify that I personally inspected the premises at the Location Address listed above on the inspection date provided on this Mitigation Inspection Form. In my professional opinion, based on my knowledge, information and belief, I certify that the above statements are true and correct.
This Mitigation Inspection Form and the information set forth in it are provided solely for the purpose of verifying that certain structural or physical characteristics exist at the Location Address listed above and for the purpose of permitting the Named Insured to receive a property insurance premium discount on insurance provided by Citizens Property Insurance Corporation and for no other purpose. The undersigned does not make a health or safety certification or warranty, express or implied, of any kind, and nothing in this Form shall be construed to impose on the undersigned or on any entity to which the undersigned is affiliated any liability or obligation of any nature to the named insured or to any other person or entity.

Name of Company: Fleet Inspections **Phone:** (954) 752-9443

Name of Inspector Michael Digiorgio **License Type** CGC **License #** 033997

Inspection Date: **5/1/24**

Signature: **Date:** **5/1/24**

Applicant /Insured's Signature *: Date: **5/1/24**

*Applicant /Insured's signature must be from the Board President and another member of the board for condo and homeowner's associations or an officer of the named insured for all other business entities.

"Any person who knowingly and with intent to injure, defraud, or deceive any insurer files a statement of claim or an application containing any false, incomplete, or misleading information is guilty of a felony of the third degree."

Inspector Notes / Comments:
Roof permit #B-2010-020226-0000
...Multiple glazed and non glazed openings are non impact rated and unprotected or have unverified protection...Recommended individual unit inspection for further credits...Shingle mansard portion of roof is not part of main roof and is not considered when determining roof characteristics and credits with carrier

PERMITS (if applicible)

Fleet Inspections provides inspection information, utilizing BuildFax by Verisk and, where feasible, checks local (city, township, or county) sites for permit details.

Limitation: Accessing detailed permit information can be extremely time-consuming due to site limitations, registration requirements, and inconsistent data entry. Consequently, there may be cases where permit details, including final dates or statuses, are not obtained.

Scope: Our process includes a basic check for permit information when easily accessible without registration or extensive time investment. We provide a permit number, when available, to facilitate further verification.

Responsibility: Should additional permit details be required, it is the responsibility of the client/homeowner to contact the issuing municipality directly—online, by phone, or in person.

Fleet Inspections' role does not extend to exhaustive searches for permit details not readily available or provided by BuildFax. This detailed verification lies with the client or underwriting department.

PHOTOS

ELEVATIONS

NON GLAZED OPENINGS

GLAZED OPENINGS

ROOF COVERING

PERMITS

Permit Details

Permit #: B-2010-020226-0000

Permit Type:	BUILDING	Applied date:	Oct 29, 2010
Description:	Reroofing R&R Flat Roof; 100 Sq. - Spray Foam to Concrete Application	Issued date:	Nov 02, 2010
Work class:	Installation of Building System	Completed date:	Apr 27, 2011
Permit status:	Complete	Status date:	Nov 02, 2010
Total sq ft:	10000		
Job Cost:	$ 85,000.00		